

MEMORANDUM

May 9, 2014

TO: Amy Colby – amyc@jparchitects.com
FROM: Steve Fisher, City of Edmonds Public Works, 425-771-0235
RE: Review comments for proposed dumpster pad

BLD20140357 – Sherwin Williams outlet, 22804 -100th Ave. W, Edmonds WA

The proposed plan indicates a concrete dumpster pad measuring 4' by 6' at the rear of the store along the alleyway. This is a suitable surface for staging the garbage container that will be serviced at this location.

However, the applicant should strongly consider lengthening the pad in order to accommodate a recycling container that will collect mainly cardboard and other accepted recyclables. These weighty metal containers have a tendency to carve out depressions and become difficult to service if left on an old asphalt surface.

I would recommend stretching the concrete pad to a minimum of 15' to adequately stage 2 side-by-side front-load containers. Let me know if you have any questions.