



ENCLOSED AREA

04S028

Box 15

CITY OF EDMONDS
BLDG. DEPT.
CONDITIONAL PERMIT

WORK- Mechanical
ADDRESS- 22814 100th Ave W.
OWNER- Susie Bears

APPROVED DATE-
BY
BLDG. OFFICIAL

KEEP THESE STAMPED PLANS ON JOBSITE FOR ALL INSPECTIONS

PERMIT NO. | SHEET / OF

APR 5 1984

HOOD: 36" - TYPE I - NON-CANOPY 3·300 = 900 CFM
DUCT: 16 GA STEEL - FULLY WELDED - 8½"x8½" FOR 1800 FPM
▨: INDICATES 22 GA STEEL ON 1" MINERAL WOOL BATS (FIRE PADS)
FLUE: 3 LAYERS 5/8" G.W.B. - 3"+ CLEARANCE AROUND DUCT
FILTERS: U.L. BAFFEL TYPE FOR GREASE
MAKE-UP AIR: BY OTHERS
FIRE SURPRESSION: BY OTHERS
FAN: 900 CFM. TOP DISCHARGE

ERICKSON MFG. ENT. 5532-208TH S.W.
LYNNWOOD 98036 776-5134
ER·1C·KI# 21217

SUZY BEARS
22814-100TH W.
EDMONDS, 98020

SCALE 3/4" = 1'	REVISIONS	BY	DATE
DATE 4-3-84			
DR'N. CKD.			
AP'VD.			
TITLE		NO.	

BRUNING 40-105