



1/2" mech.  
Gas Valve

ANSUL R102  
3.0 GALLON

Remote  
Pull

30"  
Tilt PAN  
GAS

24"  
Grill  
GAS

14"  
FRYER  
GAS

24"  
Pressure  
Cooker  
GAS

Legend

- 3/8" Pipe
- Detection Line
- Remote Pull
- Mech Gas Valve Cable

<p>CLERK OF DISTRICTS CITY OF LOS ANGELES CONTRAPTIONAL PERMIT</p>	
<p>WORK: FIRE SUPPRESSION SYST.</p>	
<p>ADDRESS: 22828 100<sup>th</sup> AVE W</p>	
<p>OWNER: OLSONS</p>	
<p>APPROVED DATE: 1-24-89</p>	
<p>BY: J. Rowe BLDG OFFICIAL</p>	
<p>KEEP THESE STAMPED PLANS ON FILE FOR ALL INSPECTIONS</p>	
<p>PERMIT NO.</p>	<p>SET</p>
<p>890066</p>	<p>OF</p>

JAN 23

DATE 16 JAN 89

CUSTOMER

NAME Olson's Edmonds  
22828 100th Ave West  
STREET Edmonds, WA. 98020  
CITY, STATE & ZIP

AUTHORIZED ANSUL DISTRIBUTOR

Distributed By:  
FIRE CHIEF EQUIPMENT CO. INC.  
NAME 13300 S.E. 30th  
STREET Bellevue, WA 98005  
CITY, STATE & ZIP (206) 641-2127 - 682-3419  
FAX NO. 562-6662

FILL IN ALL APPROPRIATE DATA BELOW AND CAREFULLY SKETCH HAZARD LAYOUT ON INSIDE

SYSTEM

Model(s) and serial numbers Ansul R102 3.0 Gallon

Location

Number of nozzles and Part No. 5 Appliance #56930, 1 Duct #56928, 1 Plenum #56927

Number of detector(s) and degree rating 4 360°F

Energy shut-off devices — type and size 1/2" mech. Gas Valve

Location

Other accessory equipment provided (pull station electric switches, etc.) and location 1 Remote Pull will be located in path of egress.

COOKING/VENTILATING EQUIPMENT

Number of duct(s) and size 1 - 72" Perimeter

Hood size and plenum size 11'

Maximum temperature determined at detector location(s)

Cooking Appliances and size of cooking surface. (NOTE: List appliances from left to right and indicate those being protected.)

- |                       |                              |
|-----------------------|------------------------------|
| 1. 30" TILT PAN - GAS | 4. 24" Pressure Cooker - GAS |
| 2. 24" Grill - GAS    | 5. _____                     |
| 3. 14" Fryer - GAS    | 6. _____                     |

COMMENTS

1. All Appliances will be protected by system and will be automatically turned off upon system discharge.

2. System will be installed I.A.W. NFPA #96, #17A and the manufacturer's instruction.

IF YOU HAVE ANY QUESTIONS PLEASE CALL 641-2127

BUILDING  
JAN 18 1989

Jim Brady

890066

OLSON'S FOODS  
FIRE SUPPRESSION SYSTEM  
22828 100th Ave W  
1/23/89  
BOX 216