SECTION 4 STARBUCKS
SCALE 1/8" = 1'-0

SECTION 4 VESTIBULE
SCALE 1/8" = 1'-0

KEY PLAN
NO SCALE

REFLECTED CEILING PLAN
SCALE 1/8" = 1'-0"

HANGER DETAIL "H"
NO SCALE

HANGER DETAIL "U"
NO SCALE

GENERAL NOTES

1) DESIGN PER NFPA 13 ORDINARY HAZZARD (EXCEPT DRAWING SEARCH AREA IN STARBUCKS - LIGHT HAZZARD) NO PAGE 100 PG 87
2) ALL PIPE DIMENSIONS ARE CUT PIPE LENGTH
3) ALL PIPE: 2" AND SMALLER - BLACK SCH 40
2 1/2" - BLACK SCH 10
4) PITCH ALL PIPING 1/4" / 10'-0".
5) PROTECTION AREA OF DRY SYSTEM:
EXISTING: 1500 SQ FT (APPROX)
ADDITIONAL: 1500 SQ FT (APPROX)
TOTAL: 3000 SQ FT (APPROX)
6) VIC FITTINGS ARE FIRELOCK UNLESS NOTED OTHERWISE

NOTE: EXIST. 2"x2"x2"x4" FIRE DEPT CONN AT PROP LINE

EXIST. VALVE DETAIL
NO SCALE

CITY OF EDMONDS
BUILDING DEPARTMENT
WORK FIRE SPRINKLER
ADDRESS 22828-100TH AVE W
OWNER OLSON'S FOODS
APPROVED DATE: 8/20/92
BLDG. OFFICIAL
PERMIT NUMBER

RECEIVED
AUG 25 1992
PERMIT COUNTER

LIST NOTES
1) SEND 36" ROD FOR EA SRS
2) SEND 2" VIC TEST CAP (1)
2 1/2" VIC TEST CAP (1)
TEST GAUGE ASSY (2)
CAN FOAM (1)

EXISTING SPRINKLERS
- EXISTING 155° DPH — QTY 10
- EXISTING 200° U.R. — 14
- RE-LOCATED 155° DPH — 2

ABBREVIATIONS

AFF	Above Finished Floor
BOB	Bottom of Beam
BOD	Bottom of Deck
BOJ	Bottom of Joist
HV	Hose Valve
N & C	Nipple and Cap
NC	Not in Contract
NTS	Not to Scale
OBJ	Open Bar Joists
PRV	Pressure Red Valve
PVC	Polyvinyl Chloride
SP	Standpipe
TOB	Top of Beam
TOP	Top of Pipe
TOS	Top of Steel
UON	Unless Otherwise Noted

TYPE OF SYSTEM ☐ WET ☒ DRY ☐ PREACTION ☐ DELUGE

- DRY PIPE VALVE
- DRY PIPE VALVE W.ACC.
- ALARM VALVE
- DELUGE VALVE
- CONTROL VALVE
- CHECK VALVE
- WATER FLOW SWITCH
- GONG OR BELL
- HYDRANT
- P.I. VALVE
- KEY GATE VALVE
- F.D.C.

SPRINKLER INFORMATION (INDICATES LENGTH TO BE USED) — SEE VARIES - SEE ELEC. CLG.

SYMBOL	QUANITY	TEMP°	MFR.	MODEL	TYPE	FINISH	ORIF.
	10	155°	VIKING	M	DRY PENDANT (5")	BRASS	1/2"
	6	200°	VIKING	M	DRY H.S.W. (3")	CHROME	1/2"
	10	200°	VIKING	M	UPRIGHT	BRASS	1/2"
	26	TOTAL THIS SHEET					

CANOPY INFORMATION

MFR.	MODEL	FINISH

APPROVING AGENCIES
EDMONDS F.D.
OWNER/ARCH.

CONTRACTOR'S LICENSE
WA. VIKI-NA-S373 NT
AK. AA 1918
MONT. 6476A

REVISIONS

VIKING
FIRE PROTECTION
VIKING AUTOMATIC SPRINKLER COMPANY
3434 FIRST AVENUE SOUTH
(206) 622-4656 SEATTLE, WA 98134 FAX: (206) 622-9319
BOISE SPOKANE LONGVIEW PORTLAND MEDFORD EUGENE

CUSTOMER: OLSON'S
ADDRESS: 22828 100TH AVE W. EDMONDS, WA
PROJECT: REMODEL / ADDITIONS

JOB NO.	DRAWN BY:	DATE	SCALE	DRAWING NO.
C920714	RAB T.	8/20/92	AS NOTED	1 OF 1